Energy performance certificate (EPC)			
Flat 10a Beechwood House NEWTOWNABBEY BT37 9SF	Energy rating	Valid until:	28 May 2035
		Certificate number:	2410-9410-1260-6199-9020
Property type	Mid-floor flat		
Total floor area	55 square metres		

Energy rating and score

This property's energy rating is C. It has the potential to be B.

See how to improve this property's energy efficiency.

Score	Energy rating	Current	Potential
92+	Α		
81-91	В		81 B
69-80	С	78 C	
55-68	D		
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Good
Wall	System built, as built, partial insulation (assumed)	Average
Window	Fully double glazed	Average
Main heating	Electric storage heaters	Average
Main heating control	Manual charge control	Poor
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in 57% of fixed outlets	Good
Roof	(another dwelling above)	N/A
Floor	(another dwelling below)	N/A
Secondary heating	Portable electric heaters (assumed)	N/A

Primary energy use

The primary energy use for this property per year is 263 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend **£740 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could save £105 per year if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2025** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

Impact on the environment		This property produces	2.4 tonnes of CO2
This property's environmental impact rating is D. It has the potential to be C. Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.		This property's potential production	2.2 tonnes of CO2
		You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.	
Carbon emissions		These ratings are based on assumptions about average occupancy and energy use. People living at	
An average household produces	6 tonnes of CO2	the property may use different amounts of energy	

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Low energy lighting	£15	£22
2. High heat retention storage heaters	£1,200 - £1,800	£82

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Ross Lindsay
Telephone	07935489951
Email	ross@emberenergyni.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK
Assessor's ID	ECMK302153
Telephone	0333 123 1418
Email	info@ecmk.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	29 May 2025
Date of certificate	29 May 2025
Type of assessment	RdSAP