

CONSENT NO: 882/20/1

FILE NO: NC 2279/19

DEPARTMENT OF AGRICULTURE ENVIRONMENT & RURAL AFFAIRS

Water (Northern Ireland) Order 1999

Consent to Discharge of Effluent

The Department of Agriculture, Environment & Rural Affairs in pursuance of the powers conferred on it by the Water (Northern Ireland) Order 1999 HEREBY CONSENTS to your making a discharge into the Waterway at Irish grid reference H 1961 2039 in accordance with the application dated 19th December 2019 in respect of a discharge of sewage effluent arising from a single domestic dwelling at Approximately 80M South of 291 Swanlinbar Road, Derrylester, Enniskillen, Co. Fermanagh, BT92 3AJ.

SUBJECT TO the following conditions:

1. Should it subsequently be revealed that the sewage treatment system has not been accurately described in the application, this consent shall be considered voidable.
2. The discharge shall consist solely of sewage effluent from the single domestic dwelling at Approximately 80 Metres South of 291 Swanlinbar Road, Derrylester, Enniskillen, Co. Fermanagh, BT92 3AJ.
3. The discharge shall not exceed 1 cubic metre per day.
4. All surface water shall be excluded from the system.

CONSENT NO: 882/20/1

FILE NO: NC 2279/19

DEPARTMENT OF AGRICULTURE ENVIRONMENT & RURAL AFFAIRS

Water (Northern Ireland) Order 1999

Consent to Discharge of Effluent

5. The sewage treatment works shall have BSEN 12566-3 certification demonstrating at least 95% removal of the influent Biochemical Oxygen Demand (BOD). The effluent from the sewage treatment works shall be discharged to the waterway via a sub-surface irrigation system which shall be not less than 40 metres in length.
6. The effluent discharged to the waterway shall not:
 - a. contain any substance which will cause the water in the underground stratum or in any waterway to be toxic or injurious to fish or other aquatic organisms;
 - b. contain any substance to such an extent as to cause the receiving waters, or any waters of which the receiving waters are a tributary, to be poisonous or injurious to the spawning grounds, spawn or food of fish in those waters, or otherwise cause damage to the ecology of those waters.
7. The consent holder shall enter into a contract with either the supplier of the sewage treatment works, or other competent body, to maintain optimum performance of the system at all times. Maintenance and service history documentation shall be available for inspection by the Department on request.
8. An alarm shall be provided to warn of power or plant failure. The consent holder shall take the necessary action as soon as possible to ensure compliance with the consent upon activation of the alarm.
9. The consent holder shall be responsible at all times for compliance with these consent conditions.
10. Facilities shall be available to ensure that a representative sample of the discharge can be obtained.
11. If the consent holder intends to change anything at the site which will impact on the content of this consent, including any accompanying site plan and/or the composition or quality of the effluent then they must make application to the Department for review of this consent. Review application should be made no later than 4 months before the proposed changes will be carried out.

CONSENT NO: 882/20/1

FILE NO: NC 2279/19

DEPARTMENT OF AGRICULTURE ENVIRONMENT & RURAL AFFAIRS

Water (Northern Ireland) Order 1999


Consent to Discharge of Effluent

12. Should the consent holder wish to transfer responsibility for this consent they must submit an application for transfer of ownership within 21 days of the transfer taking place.

INFORMATIVES

1. This discharge consent may be reviewed at any time, if the area of discharge or any area downstream, has been, or becomes designated under the European Communities Nature Conservation (Natural Habitats etc) Regulations (Northern Ireland) 1995 or the consent conditions do not meet the requirements of any other European Community Directive.
2. Compliance with the conditions of this consent ensures that this consent meets the requirements of the Urban Waste Water Treatment Regulations (Northern Ireland) 2007.
3. This consent does not grant the right of access to or use of third party land for the installation and/or maintenance of any of the treatment and drainage infrastructure to which this consent relates. It shall be the responsibility of the consent holder to obtain any third party wayleave/access permissions as may be required.

**Dated this day 13 of August 2020
Northern Ireland Environment Agency
Water Regulation Team
17 Antrim Road
Lisburn
Co Antrim**



.....
AUTHORISED OFFICER