



## **Domestic/Landlord Gas Safety Records**

No detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out

Safety inspection and reporting carried out in accordance with the Gas Safety(Installation and Use) Regulation and the Gas Industry unsafe situation procedure

Certificate Reference

25 University St F1

Certificate No:

Engineer Details							I	Installation Details					Client Details									
Trading Title Address		CMK Plumbing & Heating 64 Stewartstown Avenue Belfast						Installation Address:		Flat 1 25 University Street Belfast				Client Addres								
Gas Safe No:					e: BT119GF one No: 07711762521			Tele	phone N	Postcode: BT71FY						Telepho	one No:	Postcode: BT e No: 07809568137			71FY	
App	oliance Deta									Inspection De				. [								
	Location		Appliance Type		Make	Model	Co2 Reading	Co Reading	Flue Type	(OF/RS/FL)	Appliance Inspected (Yes/No/NA)	Combustion analysis reading (CO/CO2) ratio	Landlord's Appliances (Yes/No/NA)	Operating pressure (mbar) or	Heat Input (kw)	Safety device correct operation (Yes/No/NA)	Ventilation provision satisfactory (Yes/No)	Visual condition of flue and termination satisfactory	Flue performance test	(Yes/No/NA)	Appliance safe to use (Yes/No)	
1	Airing Cupboard		Combi Boiler	Ba	axi	Duo tec 28 HEA GC no 47-075-36	7.8	47		RS	YES	0.0006	YES	19.9 mb		YES	YES	YES	PASS	NO	YES	
2																						
3																						
5																						
										Rem	edial W		Warning Notice Fixed									
1								T.C.II	icaiai II													
2																						
3																						
4	4																					
5																						
Emergency control valve accessible:  Yes  Gas tightness satisfactory:							YES	Sign	atur	e			Gas ID number:									
Gas installation pipework visual inspection satisfactory:  Yes  Rep										rt issue	d by:											
Number of appliances tested:  1 Equipotential bonding:						Yes	Nam	ne:	Colm Mc	kenna		Signed:		- mi Knn			Date:	Wed-04-D	ec-2019			
NEXT INSPECTION DUE ON OR BEFORE: Fri-04-Dec-2020 Installation pass:							Yes	Repor	rt Rece	Received by:												
CO alarm fitted and working:  YES  Smoke alarm fitted and working							NA	Nam	ne:	John M	lagill		Signed:		Correlated			Date:	Wed-04-D	ec-2019		