

MP	Weather protection	—	Fire resisting construction 30 minutes minimum
	Fire resisting doors 30 minutes minimum	60	Fire resisting construction 60 minutes minimum
60	Fire resisting doors 60 minutes minimum	//	Internal Glazing
VL	Vertical ladder	HRL	Handrail
VP	Vision panel	GRL	Guardrail
PEL	Panic escape latches	PB	Push bar to open
EOD	Easy opening devices	OO	Outward opening
SC	Self closing devices	DS	Double swing
SC/A	Automatic releases	FRG	Fire resisting glazing
FFF	Free from fastenings	FR	Fire resisting
	Fire extinguisher water type		
	Fire extinguisher foam type		
	Fire extinguisher dry powder type		
	Fire extinguisher carbon dioxide type		
	Fire extinguisher vapourising liquid type		
	Fire extinguisher aqueous film forming foam type		
	Fire blanket		Sand bucket
	Hose reel		Fire alarm call point
	Audible warning devices		Visual warning devices
	Exchange telephone		Manual fire alarm sounder
	Internal telephone alarm system		
A	Automatic smoke detector		Door Release Break Glass
H	Automatic heat detector		
	Emergency lighting points		
EXIT	Illuminated exit boxes		
EXIT	Illuminated exit boxes with directional arrow		
E	Fire exit sign		
E	Fire exit sign with directional sign		
K	Automatic control panel threaded key (circle line door)		
I	Intumescent point (Hamron)		
FA	Fire Action (General)		Available From Construction Service Fire Section
FA2	Fire Action (Telephone Operators)		
FA3	Fire Action (Gate Keepers,Door Keepers and Receptionists)		
FA4	Fire Action (Reprographic and Print Room)		
FA5	Fire Action (Guest Bedrooms)		
N4	"Slide to open" notice		
N5	"Fire escape-keep clear" notice		
N6	"Fire door-keep shut" notice		
N7	"Push bar to open" notice		
N8	Door secured in open position notice		
N9	"Fire door-keep locked shut" notice		
IP	Indicator panel		Key in glass box
H	Hydrant	DR	Dry riser
K	Key in glass fronted box	TS	Tannoy speaker
	Outside Light		

CONSTRUCTION SHOWN IN BOLD LINES IS ACCEPTED AS PROVIDING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE, UNLESS OTHERWISE INDICATED. DOORS SHOWN IN BOLD LINES ARE ACCEPTED AS PROVIDING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE. THEY MUST BE EFFECTIVELY MAINTAINED AS SELF-CLOSING, OR AS IN THE CASE OF STORE DOORS "KEPT LOCKED SHUT" WHEN NOT IN USE. THE APPROPRIATE NOTICE IS DISPLAYED ON ALL FIRE DOORS.

HEALTH AND SAFETY EXECUTIVE
FOR NORTHERN IRELAND
83 LADAS DRIVE
BELFAST BT6 9FJ
TELEPHONE (01232) 251333

MEANS OF ESCAPE IN CASE OF FIRE

NAME AND ADDRESS
WATERSIDE TOWER
CLARENDON DOCK
BELFAST
GROUND FLOOR PLAN

FILE REFERENCE NUMBER	
COMPUTER REFERENCE CODE	6092w100
DRAWING SHEET NUMBER	1 of 6

THE FIRE SERVICES (NORTHERN IRELAND)
ORDER 1984 NO.1821

PREPARED BY	DW
DATE	APRIL 2002
SCALE	1:100
INSPECTING OFFICER	R McKAY
THIS PLAN FORMS PART OF FIRE CERTIFICATE NUMBER:	FC 003 02

FIRE CERTIFICATE FC 003 02
DRAWING No. 1 of 6
AMENDED 12th MAY 2005