

Domestic/Landlord Gas Safety Record

49A University St

Certificate Reference

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.

Certificate No:

E	ngineers D	etails		Installa	Installation Details						Client Details									
Trading Title		CMK Plumbing & Heating					lation						Client	Unive	rsity Propertie	es				
Address		64 Stewartstown Avenue					ess	49A University Street					Addres	49 un	49 university Street					
		Belfast						Belfast					Belfast							
		Post Code: BT119GF							Post Code: BT71FY						Post Code: BT71FY					
Gas Safe No:		187825 Telephone No: 07711762521				Telep	Telephone No:							Telephone No: 0780956813			37			
Appliance Details						Inspection Details														
	Locatio		Appliance Type	e Make	Model	CO2 Reading (%)	CO Reading (ppm)	FlueType (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)		
1	Airing Cup	board	Combi Boiler	Glowworm	GW BETACOM 30C	7.8	14	RS	YES	0.0002	YES	25.3 kw	YES	YES	YES	PASS	NO	YES		
2																				
3																				
4																				
5																				
Faults/Notes							Remedial Work Taken								Warning Notice Fixed					
1							carbon monoxide alarm fitted 22/4/16, replace by 22/4/26. make Kidde.									NA				
2	2																			
3	3																			
4																+				
5																				
Eme	l ergency Cont essible:	trol Valve	Yes	_	Signatures Gas ID Number:									480289	4802898					
		Pipework	Visual Inspection	n Satisfactory:	-	Report Issued By: Name: Colm Mckenna Signed:					ed:					Thu-02-Dec-2021				
Nur	nber of Appli	ances Te	sted: 1	Equipotential	Bonding: Yes	1	Report Received By:						, 4m		_					
NEXT INSPECTION DUE ON OR BEFORE: Fri-02-Dec-2022 Installation Pass: Yes						Nam		ot At Hom		Signed:					_ Date:	Thu-02-	Dec-2021			
	Alarm fitted	& working	g? YES	Smoke alarm fitted	& working? NA				This Gas Safety Report was created by Gas Checker Software all rights reserved www.gaschecker.co.uk											