

Energy performance certificate (EPC)

4b Ballyvally Road MAYOBRIDGE BT34 2ES	Energy rating E	Valid until: 2 October 2032 <hr/> Certificate number: 8009-2766-6643-3294-2914
--	---------------------------	---

Property type


A3/A4/A5 Restaurant and Cafes/Drinking Establishments and Hot Food takeaways

Total floor area

42 square metres

Energy efficiency rating for this property

This property's current energy rating is E.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

41 | B

If typical of the existing stock

109 | E

Breakdown of this property's energy performance

Main heating fuel

Grid Supplied Electricity

Building environment

Heating and Natural Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

324.01

Primary energy use (kWh/m² per year)

1830

▶ [What is primary energy use?](#)

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/2697-3610-5099-7753-4020\)](/energy-certificate/2697-3610-5099-7753-4020).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name

Chris Branagan

Telephone

07561409857

Email

info@cbenergy.co.uk

Accreditation scheme contact details

Accreditation scheme

Elmhurst Energy Systems Ltd

Assessor ID

EES/011861

Telephone

01455 883 250

Email

enquiries@elmhurstenergy.co.uk

Assessment details

Employer

CB NRG Limited

Employer address

68 Castlewellan rd Hilltown Newry

Assessor's declaration

The assessor is not related to the owner of the property.

Date of assessment

3 October 2022

Date of certificate

3 October 2022

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.