

Energy performance certificate (EPC)

18 Peters Place NEWRY BT35 8EE	Energy rating F	Valid until: 7 June 2033
		Certificate number: 0390-2278-1260-2407-8775

Property type
End-terrace house

Total floor area
91 square metres

Energy rating and score

This property's current energy rating is F. It has the potential to be E.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		
55-68	D		
39-54	E		53 E
21-38	F	38 F	
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

- the average energy rating is D
- the average energy score is 60

Breakdown of property’s energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, 100 mm loft insulation	Average
Window	Single glazed	Very poor
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, no room thermostat	Very poor
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in 90% of fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 345 kilowatt hours per square metre (kWh/m2).

► [About primary energy use](#)

Additional information

Additional information about this property:

- Stone walls present, not insulated

How this affects your energy bills

An average household would need to spend **£2,840 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £684 per year** if you complete the suggested steps for improving this property’s energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Environmental impact of this property

This property’s current environmental impact rating is F. It has the potential to be E.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year. CO2 harms the environment.

Carbon emissions

An average household produces

6 tonnes of CO2

This property produces

7.8 tonnes of CO2

This property’s potential production

5.8 tonnes of CO2

You could improve this property’s CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

► [Do I need to follow these steps in order?](#)

Step 1: Increase loft insulation to 270 mm

Typical installation cost

£100 - £350

Typical yearly saving

£68

Potential rating after completing step 1

39 E

Step 2: Draught proofing

Typical installation cost

£80 - £120

Typical yearly saving

£75

Potential rating after completing steps 1 and 2

40 E

Step 3: Hot water cylinder thermostat

Typical installation cost

£200 - £400

Typical yearly saving

£36

Potential rating after completing steps 1 to 3

41 E

Step 4: Heating controls (room thermostat and TRVs)

Typical installation cost £350 - £450

Typical yearly saving £381

Potential rating after completing steps 1 to 4 50 E

Step 5: Replace boiler with new condensing boiler

Typical installation cost £2,200 - £3,000

Typical yearly saving £124

Potential rating after completing steps 1 to 5 53 E

Step 6: Floor insulation (solid floor)

Typical installation cost £4,000 - £6,000

Typical yearly saving £109

Potential rating after completing steps 1 to 6 56 D

Step 7: Solar water heating

Typical installation cost £4,000 - £6,000

Typical yearly saving

£87

Potential rating after completing steps 1 to 7

58 D

Step 8: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost

£3,300 - £6,500

Typical yearly saving

£203

Potential rating after completing steps 1 to 8

63 D

Step 9: Internal or external wall insulation

Typical installation cost

£4,000 - £14,000

Typical yearly saving

£427

Potential rating after completing steps 1 to 9

72 C

Step 10: Solar photovoltaic panels, 2.5 kWp

Typical installation cost

£3,500 - £5,500

Typical yearly saving

£625

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name

Carleen Branagan

Telephone

07756 897853

Email

carleenbranagan@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme

Elmhurst Energy Systems Ltd

Assessor's ID

EES/020444

Telephone

01455 883 250

Email

enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration

No related party

Date of assessment

8 June 2023

Date of certificate

8 June 2023

Type of assessment

► [RdSAP](#)

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.