

Energy performance certificate (EPC) recommendation report

36 Kingsgate Street
COLERAINE
BT52 1LF

Report number
6623-9269-1129-9610-2497

Valid until
18 November 2033

Energy rating and EPC

This property's current energy rating is D.

For more information on the property's energy performance, [see the EPC for this property \(/energy-certificate/1920-9280-1499-1069-6301\)](#).

Recommendations

Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Add optimum start/stop to the heating system.	Medium
Some walls have uninsulated cavities - introduce cavity wall insulation.	Medium
Some windows have high U-values - consider installing secondary glazing.	Medium
Add weather compensation controls to heating system.	Medium
Some loft spaces are poorly insulated - install/improve insulation.	Medium

Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	Medium
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	Medium
Consider installing an air source heat pump.	High
Consider installing a ground source heat pump.	High
Consider installing building mounted wind turbine(s).	Low

Property and report details

Report issued on	19 November 2023
Total useful floor area	166 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	CLG, iSBEM, v4.1.h, SBEM, v4.1.h.0

Assessor's details

Assessor's name	Patrick Laird
-----------------	---------------

Telephone	02882247285
Email	patricklaird59@hotmail.com
Employer's name	LairdEnegy
Employer's address	32 Dublin Road, Omagh N Ireland
Assessor ID	EES/023368
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Elmhurst Energy Systems Ltd

Other reports for this property

If you are aware of previous reports for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related reports for this property.

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/hUnC3Xq1T4\)](https://forms.office.com/e/hUnC3Xq1T4) [Service performance \(/service-performance\)](#)

OGL

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



[ht \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/\)](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/)