Energy performance certificate (EPC)			
2b Tyross Gardens ARMAGH BT60 1BE	Energy rating	Valid until:	1 October 2034
		Certificate number:	2123-1115-2200-8731-8172
Property type	y type Top-floor flat		
Total floor area	6	7 square metres	

Energy rating and score

This property's energy rating is D. It has the potential to be C.

See how to improve this property's energy efficiency.

Score	Energy rating	Current	Potential
92+	Α		
81-91	В		
69-80	С		69 C
55-68	D	56 D	
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, 250 mm loft insulation	Good
Window	Single glazed	Very poor
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	(another dwelling below)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

Primary energy use

The primary energy use for this property per year is 271 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend **£1,274 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £359 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's environmental impact rating is E. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household 6 tonnes of CO2 produces

This property produces 4.6 tonnes of CO2

This property's 3.3 tonnes of CO2 potential production

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Cavity wall insulation	£500 - £1,500	£205
2. Party wall insulation	£300 - £600	£28
3. Heating controls (room thermostat)	£350 - £450	£62
4. Condensing boiler	£2,200 - £3,000	£64
5. Replace single glazed windows with low-E double glazed windows	£3,300 - £6,500	£113

Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Ryan Reavie
Telephone	07858000208
Email	<u>ryan@hannath.com</u>

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK	
Assessor's ID	ECMK306021	
Telephone	0333 123 1418	
Email	info@ecmk.co.uk	

About this assessment

Assessor's declaration	No related party	
Date of assessment	2 October 2024	
Date of certificate	2 October 2024	
Type of assessment	RdSAP	