

# Energy performance certificate (EPC)

Intertrade Ireland Kilmorey Street NEWRY BT34 2DE	Energy rating <b>C</b>	Valid until: <b>12 April 2027</b>
		Certificate number: <b>0040-1939-0313-9660-9070</b>


Property type	B1 Offices and Workshop businesses
Total floor area	1,209 square metres

## Energy rating and score

This property's energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



## How this property compares to others

Properties similar to this one could have ratings:

If newly built	<b>29 B</b>
If typical of the existing stock	<b>78 D</b>

## Breakdown of this property's energy performance

Main heating fuel	Oil
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year)	55.33
Primary energy use (kWh/m <sup>2</sup> per year)	266

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9197-4064-0331-0900-6901\)](/energy-certificate/9197-4064-0331-0900-6901).

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Robert McFarland
-----------------	------------------

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO006945
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### About this assessment

Employer	Energy Control Ireland Ltd
Employer address	1, Carrickblacker Avenue, Portadwon, Craigavon, BT63 5BB
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	6 April 2017
Date of certificate	13 April 2017